

CATHERINE D. ROBINSON  
MAYOR

JOHN ROGERS  
VICE-MAYOR

TOM FOSTER  
ACTING CITY MANAGER



COMMISSIONERS:

ELBERT TUCKER

BILL BAXLEY

JOHN SOWELL

DATE: June 11, 2018  
TO: ALL BIDDERS  
FROM: Stella Gurnee, Finance Director  
RE: Addendum #1 for ITB-06-0-2018 South Side Sewer Rehabilitation

This addendum is being issued to provide all prospective proposers with answers to questions and clarifications of the bid document and project:

The following questions were received via email, responses are shown below with questions.

1. The documents for the South Side Sewer Rehabilitation include reference to a future SCADA system. Will you be including Ignition by Inductive Automation as an option during your evaluating process?  
**No**
2. Will there be any rehabilitation of the main line, or is the project just lateral rehabilitation? If it is just lateral rehabilitation, are you requiring an ASTM F 2561 specification?  
**Please refer to project specifications that include both lateral and main line rehabilitation with sizing of pipes and estimated lengths. Page 172 and 173 of Bid Specifications.**
3. We would like to know the estimated construction cost for this project. Thank you.  
**Engineering estimate is between \$500,000 and \$750,000 for the project.**
4. What are the approximate lengths, sizes and types of the pipes to be installed on the project?  
**Please review the bid documents and specs listed on page 172 and 173 of Bid Specifications.**
5. Are there any portions of the project that will need to be Bored? Is it Open cut?  
**We do not anticipate any Bores on the project.**
6. How much is the required bid bond for the project?  
**The Bid Bond requirements are covered in Section 00 21 13 Article 8 – Bid Security (Page 58 of the bid specifications). More specifically, Bid Security is listed as “...five (5) percent of the Bidders maximum bid price and in the form of a certified check, bank money order or a Bid Bond”.**

The City of Bunnell is an Equal Opportunity Service Provider.

Post Office Box 756• Bunnell, Florida 32110-0756• 386-437-7500• Fax 386-437-7503  
[www.bunnellcity.us](http://www.bunnellcity.us)

7. Is it Heat cured or Light? CIPP?

**The method is heat cured with hot water or steam. Please reference section 03 31 15 CURED-IN-PLACE PIPE (CIPP) of Bid Documents.**

8. You'll be using pipe televising or pipe cleaning? Before and after?

**Yes, both Televising and Cleaning will be required before repairs are completed. Also, a completion video and suitable log needs to be provided to the owner. Please reference Section 03 31 20 Installation Preparations 3.1.D and Section 03 31 15 part 7.4.**

9. Do you have any further details you wish to provide?

**No further details or developments to provide.**

In all other respects, except as specifically stated herein, the subject ITB remains unchanged.

**END OF ADDENDUM #1**

The City of Bunnell is an Equal Opportunity Service Provider.

Post Office Box 756· Bunnell, Florida 32110-0756· 386-437-7500· Fax 386-437-7503  
[www.bunnellcity.us](http://www.bunnellcity.us)